



## **TEST-330**

# THREE PHASE MICROCOMPUTER PROTECTION RELAY TEST EQUIPMENT

Test-330 three phase microcomputer protection relay test equipment is the highly efficient relay tester of our company. It is produced by referring to Technical Condition for "DL/T624-2010" Microcomputer Relay & Protection Test Device issued by the original Power Department, extensively listening to the opinions of users, carefully reviewing the developing and producing experience of the former generations of products and adopting the modern latest digital technology, high precision electronic apparatus, microcomputer system and new circuit and new structure. This model relay test equipment can independently finish device test in professional fields of microcomputer protection, relay protection, excitation, metering, fault recording, etc. and is widely applied to scientific research, production and electrical test sites in electric power, petrochemical, metallurgy, railway, aviation and military industries.

### **Application**

- 1. Universities;
- 2. Power plant;
- 3. Research institutes:
- 4. Panel manufacturer;
- 5. Electrical laboratory;
- 6. Relay manufacturers;
- 7. Electrical testing center;
- 8. Electricity power bureau & power company;
- 9. Power engineering commissioning company;
- 10. Electrical Department of industrial and mining enterprises;



#### **Test Item**

4		L L .
	I – I	TECT.
Τ.		test;

4. Special test;

7. State sequence;

10. Setting group test;

13. Power direction test;

16. Frequency Protection;

19. Zero sequence protection;

2. U/I test;

5. Harmonic test;

8. Differential relay;

11. Hardware checkout;

14. Synchronization test;

17. Differential protection;

20. Impedance characteristics;

3. DC test;

6. Oscillation test;

9. Fault Recurrence;

12. Distance protection;

15. Metering instrument;

18. Low Voltage protection;



#### **Features**

- 1. 8 binary inputs, 4 binary outputs;
- 2. Intelligent self-protection function;
- 3. High-accuracy linear power amplifier;
- 4. Plentiful Binary and powerful software function;
- 5. Eight channel synchronous D/A output in a single machine;
- 6. Max AC current output is 90A, Max AC voltage output is 260V;
- 7. Synchronous output of five channel voltage and three channel current;
- 8. Embedded host machine equipped with Complex Programmable Logic Device (CPLD);
- 9. Easily complete the ABB, Siemens, AREVA, Schneider, GE, SEL, VAMP, Toshiba, NR, Sifang and other manufacturers of protective device test;
- 10. Host machine integrated single cabinet structure with big LCD screen and complete interface has obtained appearance patent;

#### **Parameters**

Electrical parameters			
Power voltage	AC220V±10% or AC110V±10%, 50/60Hz±10%		
AC current output			
Phase current output (effective value)	3 x 0-30A		
Maximum power output	260VA/phase		
Maximum parallel current output (effective value)	0-90A		
Long-term allowable working value of phase current	0-10A		
(effective value)			
Rosolution	1mA		
Allowable working time of maximum current	>11s		
Accuracy class	<±0.2%, Typital 0.05%		
AC voltage output			
Phase voltage output (effective value)	5 x 0-130V		
Line voltage output (effective value)	0-260V		
Maximum power output	70VA/phase		
Rosolution	1mV		
Accuracy class	<±0.2%, Typital 0.05%		
Power output			
Accuracy class	<±0.2%, Typital 0.05%		
Frequency output			
Output frequency	0-1050Hz		
Frequency error	<±0.001Hz		





Electrical parameters - continued  Phase angle output	
Phase angle	-180.000°-0-180.000°, 0.000°-360.000°
Phase error	<±0.1°, Typital 0.05°
DC current output	120.1 , Typitai 0.03
Output range	-10 to 10A or 3 x 0 to ±10A
Maximum power output	200VA
Accuracy class	<±0.2% , Typital 0.05%
DC voltage output	(201270 ) Typical 0.00770
Output range	0-300V or 5 x 0 to ±130V
Maximum output power	130VA
Accuracy class	<±0.2% , Typital 0.05%
Binary input	
Idle contact	1-20mA, 24V (DC)
Electric potential contact	250V/0.5A (DC)
Binary input number	8PCS
Binary output	
Idle contact	250V/0.5A (DC)
Binary output number	4PCS
Function	
Waveform distortion	<±0.3% (fundamental wave)
Time measurement	0.1ms-999999.999s
Time error	<40µs
Superposed harmonic wave	0-21times
GPS	Optional
LCD	8 inch color TFT LCD
Key	24pcs key
Communication port	RS232, USB, VGA, 10/100M LAN
Standard	IEC 61010, IEC 61000, IEC 61326
Mechanical parameters	
Dimensions (L×W×H) (mm)	360x195x375
Weight (kg)	16.6
Environmental conditions	
Operation temperature	0°C to 50°C
Storage temperature	-25°C to 70°C
Humidity range	Relative humidity 5 95 %, non-condensing



# **Testing ANSI standard device**

<b>ANSI Standard Device</b>		
List of Device Numbers	Relay or Circuit Rreaker	FUNCTION
2	Time Delay Starting or Closing Relay	Yes
21	Distance Relay	Yes
24	Over-Excitation Relay	Yes
25	Synchronizing or Synchronism-Check Device	Yes
27/27N	Undervoltage Relay	Yes
30	Annunciator Relay	Yes
32	Directional Power Relay	Yes
36	Polarity or Polarizing Voltage Devices	Yes
37	Undercurrent or Underpower Relay	Yes
40	Field Relay	Yes
46	Reverse-phase or Phase-Balance Current Relay	Yes
47	Phase-Sequence Voltage Relay	Yes
50/50N	Instantaneous Overcurrent or Rate of Rise, Relay	Yes
51/51N	AC Time Overcurrent Relay	Yes
52	AC Circuit Breaker	Yes
53	Exciter or DC Generator Relay	Yes
55	Power Factor Relay	Yes
56	Field Application Relay	Yes
58	Rectification Failure Relay	Yes
59/59N	Overvoltage Relay	Yes
60	Voltage or Current Balance Relay	Yes
61	Machine Split Phase Current Balance	Yes
62	Time-Delay Stopping or Opening Relay	Yes



ANSI Standard Device - continued				
List of Device Numbers	Relay or Circuit Rreaker	FUNCTION		
64	Ground (Earth) Detector Relay	Yes		
67/67N	AC Directional Overcurrent Relay	Yes		
68	Blocking Relay	Yes		
74	Alarm Relay	Yes		
76	DC Overcurrent Relay	Yes		
78	Phase-Angle Measuring or Out-of-Step Protective Relay	Yes		
79	AC Reclosing Relay	Yes		
81/81U/O/R	Frequency Relay	Yes		
82	DC Reclosing Relay	Yes		
85	Carrier or Pilot-Wire Receiver Relay	Yes		
86	Lockout Relay	Yes		
87	Differential Protective Relay	Yes		
91	Voltage Directional Relay	Yes		
92	Voltage and Power Directional Relay	Yes		
94	Tripping Relay	Yes		

## **Accessories**

